

FY 2016 SANITARY SEWER OVERFLOW REPORT

The City of Oxford reports Sanitary Sewer Overflows in accordance with the North Carolina General Statutes and NCDENR guidance. Discharge of 1,000 gallons or more of untreated waste to the surface or water of the State requires Publication of Notice of Discharge. Oxford has had three reportable SSOs that have reached surface water during this fiscal year. When SSOs occur it is standard practice to unstop blockage, clean up and disinfect spill area, Pump creeks when necessary, Inspect by CCTV, Repair, refurbish and renovate the affected area.

OVERFLOWES

From 6/24/16 to 4/27/17 there were seven overflows in which three were reportable to the State. The three locations were; 1. The Outfall at Fairway Drive. 2. The outfall behind the 200 block of Maple Drive. 3. The 100 block on Coleman St. All were unstopped and cleaned.

MAIN BLOCKAGES ONLY

From 7/27/16 to 4/25/17 there were twelve main line blockages in different locations due to sand, roots, and debris. All were unstopped and cleaned.

Stevie Inscoe: Collection System ORC.

There is a notation on the monthly water bill that this report is found on the City Webb site. www.oxfordnc.org